



NATIONAL EMERGENCY RESPONSE FRAMEWORK IN CANADA

THUY NGUYEN

Emergency Management Specialist
Canadian Nuclear Safety Commission

**2024 Spring International
Ramp Users' Group Meeting**

April 16, 2024
Seoul, South Korea



Outline:



- Canadian National and Organizational Emergency Response Framework
 - Acts and Regulations
 - National Emergency Response Framework
 - Protective Action Strategy in Canada
- CNSC Emergency Operation Centre Response
 - Response Mandate
 - Response Structure and Staffing
 - Concept of Operations for Reactor Accident Response
 - Assessment & Prognosis (A&P) Methodology and Supporting Technical Tools
- National Exercises
- EPREV
- Summary



Canadian National and Organizational Emergency Response Framework



Canada: A Constitutional Monarchy




- The ***Constitution Act***:
 - Canada is a federation consisting of 10 provinces and 3 territories.
 - Establishes fundamental principles and division of powers between the federal government and provincial/territorial governments
- The ***Emergency Management and Civil Protection Act***:
 - Responsibilities for emergency management are shared
 - Provinces and territories have the primary authority in an emergency
 - Province to formulate an emergency plan for emergencies arising in connection with nuclear facilities
- The ***Nuclear Safety and Control Act***:
 - Provides the Canadian Nuclear Safety Commission (CNSC) with its regulatory authority
 - ✓ Regulate the use of nuclear energy and materials to protect the health, safety and security and the environment
 - ✓ Implement Canada's international commitments on the peaceful use of nuclear energy
 - ✓ Disseminate objective scientific, technical and regulatory information to the public



CNSC Regulatory Framework




- **Nuclear Safety and Control Act (NSCA)**
 - Enabling legislation
- **Regulations**
 - High-level requirements
- **Licences, Licence Conditions Handbooks, Certificates**
 - Facility and/or activity specific requirements
- **Regulatory Documents**
 - Include requirements and guidance






CNSC Regulatory Document 2.10.1, Nuclear Emergency Preparedness and Response


- Sets out EPR requirements for Class I nuclear facilities and uranium mines and mills
- Aligned with IAEA guidance and incorporated Fukushima lessons learned
- Current version was published in 2016 and is undergoing review and updates as part of the SMR readiness REGDOC
 - Application of the graded approach that is commensurate with risk
 - An alternate approach may be proposed to demonstrate the intent of a requirement is addressed
 - EP Program to be driven/based on the facility's planning basis



Canadian National Emergency Response Framework



Coordination of Emergency Response Plans/Jurisdictions



FERP: Federal Emergency Response Plan
 FNEP: Federal Nuclear Emergency Plan
 SOREM: Senior Officials Responsible for Emergency Management
 DM EMC: Deputy Minister Emergency Management Committee
 ADM EMC: Assistant Deputy Emergency Management Committee
 DG EMC: Director General Emergency Management Committee

Protective Actions Strategies-Two Different Approaches



Bruce Nuclear Generating Station



Darlington Nuclear Generating Station



Pickering Nuclear Generating Station



Point Lepreau Generating Station

Ontario

- Protection strategy is dependent on the type of the accident:
 - **DBA:** Sufficient time is available to determine the nature of the hazards posed through analysis of the plant status and plant data
 - **BDBA/Severe Accident:** Sufficient time may not be available prior to a radioactive release to undertake analysis, and default protective actions are defined for specific areas in the PNERP Implementing plans
- Protective action decision-making is categorized according to emergency phases:
 - **Early Phase:** Protective measures are based on conservative estimate of the situation. Based on the HC Generic Criteria for actions based on dose projections
 - **Intermediate Phase:** Based on real measurements using OILs

News Brunswick

- Automatic protective actions in the automatic action zone are triggered by emergency action levels
- **Immediate evacuation of Automatic Action Zone at the declaration of a General Emergency**
- During the early stages of an emergency, after urgent protections have been implemented but before measurements are available, GC for exposure control can be compared to projected dose to confirm, that the pre-determined arrangements to protect populations are adequate
- OILs are used to support decision-making post-release to identify the need for or confirming the adequacy of protective actions

Protective Actions and Basis of Decision-Making

Potential Exposure Pathways	Basis of Decision-Making			Protective Actions	
	Early Response	Intermediate Response	Intermediate/Transition Response		
External radiation from plume	Based on plant conditions and dose projection models			<ul style="list-style-type: none"> Sheltering Evacuation Control of access 	
Inhalation of radioactivity in the plume				<ul style="list-style-type: none"> Sheltering KI Evacuation Control of access 	
Contamination of skin and clothes		Based on actual measurements			<ul style="list-style-type: none"> Sheltering Evacuation Decontamination of persons
External radiation from ground deposition			Based on actual measurements and sampling		<ul style="list-style-type: none"> Evacuation Temporary Relocation Decontamination of land and property
Inhalation of resuspended radioactivity					<ul style="list-style-type: none"> Relocation Resettlement Decontamination of land and property
Ingestion of contaminated food and water					<ul style="list-style-type: none"> Food and Water Controls

Offsite Emergency Planning Zones

IAEA Planning Zones	HC/CSA Planning Zones	NB EMO Planning Zones (1 Unit station)	Ontario EMO Planning Zones (Multi-units stations)
Precautionary Action Zone	Automatic Action Zone	4 km	3 km
Urgent Protective Action Zone	Detailed Planning Zone	20 km	10 km
Extended Planning Distance	Contingency Planning Zone	50 km	20 km
Ingestion and Commodities Planning Distance	Ingestion Planning Zone	57 km	50 km



CNSC Emergency Operations Centre (EOC) Response



CNSC Emergency Response Mandate



Same role before, during and after an emergency

- Provide assurance that appropriate actions are taken to limit the risk to health, safety, security and the environment

Two missions plus one

- Maintain regulatory oversight of licensees' emergency response activities
- Participate in Canada's whole-of-government response
- Provide support to the international response as required
- **Provide reactor accident A&P and source terms prediction for both domestic and international reactor emergencies for Canada**

CNSC Roles and Responsibilities



Manage the CNSC
EOC Response

Monitor accident
progression, perform
forecast/worst case
analyses, and assess
protective actions and
consequences

Provide technical
advice and support
to stakeholders

Coordinate and
cooperate with
external organizations

Enforce relevant regulatory
and
licence conditions

Communicate on the event
response

**Not unlike what we do in “normal” circumstances,
only more rapidly...**

CNSC Emergency Response Level



Enhanced monitoring

Enhanced oversight

Key program staff and specialists
(2 to 5 Staff)

Partial activation

Core functions

Limited staff within the EOC
(15-20 Staff)

Full activation

All EOC functions

Fully staffed
(30-40 Staff)


Pre-established EOC activation triggers /
Director general or vice-president decision to activate



MIR3 Notification by CNSC
Duty Officer to Activate the
EOC



CNSC Nuclear Response Organization Structure



EET: Executive Emergency Team
 ERO: Emergency Response Organization

In Event of a Reactor Nuclear Emergency



The CNSC Nuclear Emergency Organization will activate in accordance with the CSNC Nuclear Emergency Response Plan

The Reactor Safety Group will be activated to assess the reactor and plant state to:

- predict possible accident progression for key events and timelines
- predict release of fission products
- provide technical info to support the CNSC EOC and offsite response
- liaise with international stakeholders to provide technical information
- forms the FNEP TAG Risk Assessment Group

3 Key Questions

1. What is the onsite situation?

Assess the accident scenario and determine whether the licensee is taking appropriate actions.

2. What is the risk?

Determine if a radiological release would occur and what its magnitude would be.

3. What actions are being taken?

Determine the offsite consequences and provide support to the offsite organizations in order to ensure appropriate actions are taken.



Reactor Safety Group

- Activated to perform accident assessment and prognosis for nuclear reactor accidents
- 8–10 Technical subject matter experts in:
 - Severe accident phenomenology
 - Source terms estimation/modelling
 - Safety systems design/analysis
 - Reactor physics and fuel behaviour



CNSC Assessment & Prognosis (A&P)






CNSC WebEOC: CNSC Response Coordination Tool

Onsite info


Accident assessment: Diagnosis and prognosis

Technical info products


4D/4P METHODOLOGY




1. Fuel matrix and sheath



2. Heat transport system (HTS)



3. Calandria vessel



4. Containment

CANDU 4D/4P Fission Products Barrier

CNSC A&P Products




Onsite Information/Plant Data

CNSC Site Staff

Hourly Plant Transmittals

Posted Date/Time	Title
09/28/2023 10:30:25	PNERP Notification 0950
09/28/2023 09:57:56	Form 10460 Station Parameters - 0916
09/28/2023 09:51:37	Station Parameters Form 10460
09/28/2023 09:50:47	Form 10459 - Station Parameters 0945
09/28/2023 09:48:22	SAMG System Status Summary - 0830
09/28/2023 09:30:46	SACRG1 B2 IFB Diagnostic Parameters 0830
09/28/2023 09:30:20	Station Parameters DO 0839 Pickering
09/28/2023 09:16:20	Station Parameters 2023_09_2809_03_16_1_845
09/28/2023 09:12:50	SACRG-1 Unit Diagnostic Parameters - 0649
09/28/2023 09:10:02	Form 10460 - Station Parameters - 0839
09/28/2023 09:04:27	SACRG-1 Unit Diagnostic Parameters - 0127
09/28/2023 07:40:57	N-FORM-10471 SEPT 28 0745
09/28/2023 07:40:20	N-FORM-10471 SEPT 28 0645
09/28/2023 07:39:51	N-FORM-10468 SEPT 28 2023 0530
09/28/2023 07:39:21	N-FORM-10468 SEPT 27 2023 1630
09/28/2023 07:38:51	N-FORM-10464 SEPT 28 2023 0730



CNSC A&P Technical Tools

4D/4P Automated Tool

Nuclear Generating Station Selection Screen

Plant Data Trending Tool

4D/4P Site-Specific Grids

CNSC In-House Tools

CHAT

Severe Accident Handbook

Severe Accidents Handbook Point Lepreau

BAYLOCA: For Irradiated Fuel Bay Accident

Licensee Tools

REPRESS: For multi-unit CANDU NPPs

CNSC A&P Products

Pre-Severe Accident Grid

Post-Severe Accident Grid

Source Terms Determination

Reactor Assessment Tool Product (IAEA RAT)

CNSC Technical Product to External Stakeholders


VETA-CNSC CANDU Source term Software



- Visual EOC Source Term Assessment
- Developed in 2011 by CNSC specialists
- Symptoms-based and designed to reproduce results of MAAP-CANDU
- Aligns with CNSC 4D/4P A&P (based on the CANDU's 4 core damage states)
- Predicts accident releases for both design basis accidents and beyond design basis accidents
- Participated in the International Benchmarking of Fast-Running Software Tools Used to Model Releases During Nuclear Accidents

The screenshot shows the VETA software interface. On the left is the 'Core Damage States' dialog box with various input fields for reactor shutdown, accident initiation, and core damage states. On the right is a Notepad window titled 'releases.txt' containing a list of radionuclides and their corresponding release values.

Radionuclide	Release Value
release	1 1655.000
KR-85	2.3920000E+16
KR-85M	3.3960000E+18
KR-87	6.7200001E+18
KR-88	9.4800002E+18
XE-131M	1.2400000E+17
XE-133	2.4439999E+19
XE-133M	7.5600001E+17
XE-135	2.1640000E+18
XE-138	2.0720000E+19
I-131	9.1932621E+14
I-132	1.3758835E+15
I-133	1.9504622E+15
I-134	2.1274947E+15
I-135	1.8200175E+15
CS-134	7.8266960E+12
CS-136	1.5125399E+13
CS-137*	1.972031E+13
TE-129M	3.6029289E+12
TE-131M	1.3883700E+13
TE-132	1.3417804E+14
SB-127	8.3861276E+12
SB-129	2.9320387E+13
BA-140	0.0000000E+00
SR-89	7.6096335E+12
SR-90	1.4629131E+11
SR-91	0.0000000E+00
RU-103	1.1305741E+13
RU-105	9.1315597E+12
RU-106*	1.3138264E+12
Y-91	9.4110965E+12
MO-99	1.7672985E+13
LA-140	1.6772253E+13
CE-144*	4.1620034E+12
H-3	7.6800001E+17



VETA Tools Suite:

- SCALE (Standardized Computer Analyses for Licensing Evaluation)
 - Calculates Initial inventory for 'Non-Standard Core' or for Fuel Machine
 - Calculates decay of nuclides included in the source term
- RASCAL (Radiological Assessment System for Consequence Analysis)

- VETA Source term is imported into RASCAL for CNSC dose assessment
- VETA Source term provided to FNEP for dose assessment

FNEP TAG Response



- Source term characterisation – based on information provided by the CNSC
 - How much radioactive material could be/has been released?
 - How might this change over time?
- Hazard prediction – modelling
 - Where might a radioactive release go?
 - What are the potential pathways and exposures?
- Hazard assessment – measurements / modelling
 - Where has the radiation actually gone?
 - What are the potential pathways and exposures?
- Hazard impact
 - What is the impact on population and environment?
 - What are recommended protective actions?
- Information sharing/Situational awareness/Common Operating Picture
 - Mapping & situational awareness reports
 - Shared with other EOCs and Global Affairs Canada




Accident and Source term Information

Product 1: Reactor Assessment Product

- Graphical summary status of the fission product barriers and the main safety function integrity.
- Share with the IAEA and the Federal Nuclear Emergency Plan-Technical Assessment Group
- Upon request, share with international regulators and the provincial ECC

Product 2: Source Terms Prediction Product

- Activity of released radio nuclides (32 isotopes)
- Release time, duration, and release height
- Share with the Federal Nuclear Emergency Plan-Technical Assessment Group for dose consequence assessment



Modelling



Radiation Monitoring Networks




Ground Surveys and Population Monitoring

FNEP TAG Product

EXERCISE - EXERCISE - EXERCISE Grabenheinfeld (DL) - 5 FNEP TAG Report: Modelling Results - Grabenheinfeld, Germany (DE)			
EVENT NAME: Exercise Synergy Challenge 2021	FNEP USE	Product status	Approval status
Modelling Results: Protective Action Projections	TACS	<input checked="" type="checkbox"/> Draft	Unapproved
RFI #: Requested (D/T):	Requested by: OCP	<input checked="" type="checkbox"/> Approved by: RA Lead	Published (D/T):
N/A	Sit Rep	Signature:	
	Other (specify)		
<input type="checkbox"/> PLANNING	<input type="checkbox"/> PRE-RELEASE	<input checked="" type="checkbox"/> DURING RELEASE	<input type="checkbox"/> POST RELEASE
Modelling Results: Protective Action Projections - Grabenheinfeld, DE This Report replaces the previous modelling product: N/A. This Report is only valid until the next one is released.			
Report summary: These maps show where the Total Effective Dose (TED) after 7 days is projected to exceed the Generic Criteria (GC) for evacuation of 100 µSv/h in 7 days (top), where TED after 2 days is projected to exceed the GC for sheltering of 10 µSv/h (middle) and where the equivalent dose to the thyroid (H _T) is projected to exceed the GC for iodine Thyroid Blocking (ITB) of 50 µSv (bottom) based on an estimated source term and single model run at the Grabenheinfeld Nuclear Power Plant (NPP) in Germany (DE) starting 05 March 2021 at 01:00 CET. Dose is estimated for the most sensitive receptor, in this case the 5-year-old child.			
Evacuation	Legend	Information displayed each map:	
	<ul style="list-style-type: none"> Grabenheinfeld NPP Sectors where evacuation has already been ordered and/or implemented ≥ 100 µSv/h effective dose GC for evacuation from Health Canada (2018) projected to be exceeded < 100 µSv/h effective dose GC for evacuation from Health Canada (2018) not projected to be exceeded 	<ul style="list-style-type: none"> Emergency Planning Zones (EPZs) from the recommendations by the German Commission on Radiological Protection (SSK, 2014). Dose projections to the most sensitive receptor: TED: <input type="checkbox"/> 1YD <input type="checkbox"/> 5YD <input type="checkbox"/> 10YD <input type="checkbox"/> Adult EPZs where protective actions are assumed to have already been ordered and/or implemented by authorities (SSK, 2014). 	
Sheltering	Legend	Location:	
	<ul style="list-style-type: none"> Grabenheinfeld NPP Sectors where sheltering has already been ordered and/or implemented ≥ 10 µSv/h effective dose GC for sheltering from Health Canada (2018) projected to be exceeded < 10 µSv/h effective dose GC for sheltering from Health Canada (2018) not projected to be exceeded 		
ITB	Legend	Produced by:	
	<ul style="list-style-type: none"> Grabenheinfeld NPP Sectors where ITB has already been ordered and/or implemented ≥ 50 µSv/h equivalent dose to the thyroid GC for ITB from Health Canada (2018) projected to be exceeded < 50 µSv/h equivalent dose to the thyroid GC for ITB from Health Canada (2018) not projected to be exceeded 	Federal Nuclear Emergency Plan Technical Assessment Group RA Group Lead FNEP Duty Officer: fnep-dfo@nrc.ca Duty Officer (24/7): 815-854-8851 Health Canada	
Note: that this map is a prediction based on an estimate of the source term and release conditions of the nuclear emergency. The assessment of the impacts of the emergency may change with time. Predictions should be confirmed using measurements wherever possible. Please check the FNEP OCP site (https://ocp-pco.gc.ca/ocp-pco/717-4710) to make sure you have the latest report.			

Aerial Surveys



International Accident Support



- Under IAEA RANET agreement, Canada provides the following support:
 - PHWR Nuclear Power Reactor Accident Analysis, Radiation Survey, Source Search and Recovery, and Dose Assessment
- MOUs with other regulators for collaboration and support, including:
 - US NRC, UK ONR, FRA ASN/IRSN, KOR NNSC/KINS, JAP NSA



National Exercises





National Exercises

- REGDOC 2.10.1 requires Nuclear Power Plants to conduct a full-scale exercise every 3 years
 - Participation to include the operator, offsite organizations/province, FNEP, and the regulator
 - Usually takes 1 year to prepare and develop a full-scale exercise
 - Number of participating response organization could range from 20-50
- Canada routinely exercise with our international counterparts and participate in the ConvEx and INEX exercise series

Recent National Exercises since 2017

- **2017:** Darlington, Pickering NPPs
- **2018:** Pt. Lepreau NPP
- **2019:** Bruce, Darlington NPPs
- **2020:** Darlington, Pickering, Bruce NPPs
- **2021:** Pt. Lepreau NPP
- **2022:** Darlington, Bruce NPPs
- **2023:** Bruce, Pickering NPPs

Exercise Unified Response, May 2014



- A national exercise at the Darlington Nuclear Generating Station
 - 3 Days full-scale exercise
 - A severe accident that required a coordinated response from 50 Canadian government agencies and regional organizations
- The IAEA IEC fully participated
 - Tested its assessment of situation and prognosis
 - Conclusions were discussed with the official counterparts at the CNSC
 - First time the IEC tested its A&P in a Member State national level exercise





"Taking part in this large-scale Canadian national exercise helped us sharpen our skills by testing our ability to provide an assessment and prognosis in a real-time scenario," said Elena Buglova, Head of the IEC. **"This was the first time the IEC was given an opportunity to test its capabilities to perform assessment and prognosis in a Member State national-level exercise, and we found it to be a useful complement to our own exercises."**

EPREV-Canada 2019 & Follow-up 2023



- Canada hosted an **Emergency Preparedness Review Mission** in June 2019
 - First G7 country to host an EPREV mission
 - A peer review conducted by an international team of experts under the coordination of the IAEA
 - Based on IAEA Safety Standards and guidance in EPR
 - Findings included: 6 recommendations, 6 suggestions and 5 good practices
- A Follow-Up Mission was conducted in June 2023 with the focus
 - Focused on the outcome of the Action Plan to address the EPREV findings
 - All recommendations and suggestions from 2019 are closed





Summary

- Nuclear emergency management in Canada:
 - A shared responsibility between the different levels of government
 - Established and maintained through a mature regulatory and EPR regime, that is fully aligned with IAEA safety standards and associated international conventions
 - A&P is an important component to support protective actions recommendations for the federal response
 - EPREV and Follow-Up missions found that Canada EPR system is well-developed and mature across all levels of government
 - Continuous improvement based on lessons learned from national and international exercises, and from real event response



Thank you

